

- H1 -Dependent upon the engineers determination of the allowable amount of sediment and trash accumulation. Supporting calculations must be supplied.
- -vertical path length for average particle.
- -horizontal path length for an average particle. If the inlet is tangental to the spool then the horizontal path length may be taken as the circumference of the inside of the spool.
- It should be noted that this drawing depicts a minimum requirement and other designs may be considered as long as these minimum requirements are met or exceeded.

City of Rio Rancho Department of Public Works

TYPICAL WATER QUALITY MANHOLE REQUIREMENTS

DWG, NO, DR-01

JAN 05, 2010